



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	Page 1 of 2
afp - 2453	24-Sep-2010	Number 19	Issue date 21-Mar-2025	30-Apr-2026

Product designation

Firex, FXAF Series, 9 litre, foam type portable fire extinguishers

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Firex Distribution (Australia) Pty Ltd
14 Distribution Place, SEVEN HILLS, NSW, AUSTRALIA, 2147

Registrant

Firex Distribution (Australia) Pty Ltd
14 Distribution Place, SEVEN HILLS, NSW, AUSTRALIA, 2147

Producer

Firex Distribution (Australia) Pty Ltd
14 Distribution Place, SEVEN HILLS, NSW, AUSTRALIA, 2147

Conformance criteria and evaluation

The Firex, FXAF Series, 9 litre, foam type portable fire extinguishers have been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian/New Zealand Standard AS/NZS 1841.4:2007, 'Portable fire extinguishers - Specific requirements for foam type extinguishers'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. This equipment should only be used for the classification of fire for which it is rated. (Ref.: AS/NZS 1850).
- ii. Foam type fire extinguishers are suitable for use on Classes A and B fires; should not be used on fires involving live electrical equipment or in any sort of electrical environment.

Issued by

Kai Loh

Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	Page 2 of 2
afp - 2453	24-Sep-2010	Number 19	Issue date 21-Mar-2025	30-Apr-2026

Technical specification

The following details are a representative extract of the technical specification for the Firex, FXAF Series, 9 litre, foam type portable fire extinguishers and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

Model:	FXAF
Agent capacity:	9.0 litres
Agent type:	Tridol S 6% AFFF
Rating:	3A:20B
Operating pressure:	1000 kPa
Discharge time:	45 seconds
Physical characteristics	
Height:	630 mm
Diameter:	180 mm
Total mass:	12.5 kg
Construction	
Cylinder:	Stainless Steel, UV powder Coated
Valve:	Chrome plated Brass,
Handle:	Stainless Steel
Hose:	EPDM
FERN No.:	5665.04-100

Supplementary information

Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference		Title / description	Date issued (or date validated)	Source
Ident. type	Ident.			
Certificate	A854DE3209DA70EDC A2584120024A2AE	global-mark® Certificate of Approval AS/NZS 1841.4-2007 : Portable fire extinguishers - Specific requirements for foam type extinguishers Firex Distribution (Australia) Pty Ltd Unit 5, 11 Packard Avenue Castle Hill NSW 2154 AUSTRALIA	25-Jun-2019	Global-Mark Pty Ltd, AU
Catalogue	2018 v5	Firex Product Catalogue	17-Sep-2018	Firex Distribution (Australia) Pty Ltd, AU